



## NATIONAL CENTRE FOR EARTH SCIENCE STUDIES

P.B. No. 7250, AKKULAM, MEDICAL COLLEGE P.O.,  
THIRUVANANTHAPURAM-695 011, KERALA, INDIA

Tel: 91-471-2511531

e-mail: [ncesspurchase@gmail.com](mailto:ncesspurchase@gmail.com)  
[purchase@ncess.gov.in](mailto:purchase@ncess.gov.in)

### CORRIGENDUM No.1

dt. 05/08/2025

File No. : PUR-PROC/136/2025-PUR-NCESS

GeM Tender No. : GEM/2025/B/6503678

Description of stores : **High Performance Computer Workstation - 1 No**

The following technical specifications are added to the tender.

BoQ Sl. No.	Tender specifications	Modified specifications
3	1 KVA UPS	Capacity (VA) / Power Factor: 1000 / 0.6 Voltage (VAC): 100~300VAC Over Voltage Transfer (Adjustable): 270V / 280V AC Frequency (Hz): 50 / 60Hz $\pm$ 10Hz Auto Sensing Voltage AVR Mode: 200~245V Voltage Battery Mode: 230VAC $\pm$ 10% Frequency (Hz) on Battery: 50/60Hz $\pm$ 0.1Hz Waveform: Simulated Sine Wave or better No. of PC Support (LCD Monitor): 2 Nos. or higher Transfer Time (ms): 4-8 ms Typical or better Internal Battery: 2x12V/7AH with 20-30 Min Backup

There is no change in other terms and conditions.

Yours sincerely,

Sd/-

Deputy Manager